



NOTES:

1. MAXIMUM 3 - POSITION METER SOCKETS ONLY AND OF A TYPE APPROVED BY HORIZON UTILITIES.
2. THE METER BASE SHALL BE SUPPLIED AND INSTALLED BY THE CUSTOMER.
3. ALL METER BASE INSTALLATION SHALL BE IN ACCORDANCE WITH THE ONTARIO ELECTRICAL SAFETY CODE.
4. THE SERVICE ROUTE AND METER BASE LOCATION SHALL BE APPROVED BY HORIZON UTILITIES.
5. THE SERVICE TRENCH INSTALLATION SHALL BE AS PER STD. 25U-202.1.
6. ENSURE LIBERAL USE OF "PENETROX A" ON CONNECTION BETWEEN THE ALUMINUM CONDUCTORS/LUGS AND TERMINALS OF METER BASE.
7. ENSURE ALUMINUM CONNECTIONS ARE WELL TIGHTENED TO THE TERMINALS OF METER BASE (23 FT-LBS OF TORQUE).
8. THE SERVICE CONDUIT SHALL HAVE A PLASTIC (INSULATING) BUSHING INSIDE THE METER BASE.
9. NO ATTACHMENT SHALL BE PERMITTED TO THE CONDUITS.
10. THE METER BASE AND CONDUITS SHALL HAVE A 100 MM RADIAL OBSTRUCTION FREE AREA FROM GAS METERS, COMMUNICATION STRUCTURES, FENCES, TREES, PLANTS, SHRUBS AND OTHER STRUCTURES THAT OWNERS MAY INSTALL.
11. UNIT # MUST BE PERMANENTLY MARKED ON METER BASE AND CONNECTED SERVICE PANEL.
12. SYMBOL "◁▷" IS FOR HORIZON UTILITIES CORPORATION'S INTERNAL USE. ◁▷



DRAWING STATUS	BY	DATE DD/MM/YY
DRAWN:	JM	01/05/07
CHECKED:	ND/AT	09/06/07
APPROVED:	BM	09/06/07

MULTIPLE METERS INSTALLATION - MOUNTING DETAILS

(RESIDENTIAL - CONDOMINIUM ONLY)
LINEAR DIMENSIONS SHOWN IN MILLIMETERS

DRAWINGS NOT TO SCALE

REFERENCE DRAWINGS:
25U-202.1

DRAWING #	SHEET#	REVISION#
27-01C	1	1