



**NOTES:**

1. A FULL-SIZED NEUTRAL SUPPLY CONDUCTOR SHALL BE CONNECTED TO AN INSULATED NEUTRAL TERMINAL INSIDE THE METER BASE.
2. STANDARD PHASING IS RED, BLACK AND BLUE FROM LEFT TO RIGHT AND TOP TO BOTTOM.
3. THE CUSTOMER MUST PROVIDE UNRESTRICTED ACCESS TO THE METERING AND MAY BE REQUIRED TO PURCHASE A HORIZON UTILITIES CORP. KEY BOX TO BE INSTALLED ON SITE.



DRAWING STATUS	BY	DATE DD/MM/YY
DRAWN:	JM	28/06/07
CHECKED:	AV	15/09/05
APPROVED:	CR	15/09/05

**SERVICE ENTRANCE AND METER INSTALLATION 200A-120/208V OR 600/347V 3-PHASE 4-WIRE**

LINEAR DIMENSIONS SHOWN IN MILLIMETERS

DRAWINGS NOT TO SCALE

DRAWING #	SHEET#	REVISION#
27-02	1	0

REFERENCE DRAWINGS: