



NOTES:

1. A 5 JAW SOCKET METER BASE WITH AUTOMATIC CLOSING DEVICE SHALL BE MOUNTED ON OUTSIDE WALL.
2. INSTRUMENT TRANSFORMER ENCLOSURE SHALL BE EQUIPPED WITH:
 - A. REMOVABLE INNER BACKPLATE.
 - B. HINGED DOOR, FULL HEIGHT.
 - C. PROVISION FOR PADLOCK AND SEAL.
 - D. MADE OF 14 OR 16 GAGE STEEL.



DRAWING STATUS	BY	DATE DD/MM/YY
DRAWN:	JM	28/06/07
CHECKED:	AV	15/09/05
APPROVED:	CR	15/09/05

**METERING INSTALLATION 400A-120/240V
1-PHASE**

LINEAR DIMENSIONS SHOWN IN MILLIMETERS

DRAWINGS NOT TO SCALE		REFERENCE DRAWINGS:	
DRAWING #	SHEET#	REVISION#	
27-06	1	0	